

## Fire Alarm and Fire Suppression System Plan Reviews

All fire alarm, fire sprinkler and fire suppression system plans shall be submitted to the Fire Marshal's Office (FMO) for review and permit. This includes commercial cooking hoods and hood extinguishing systems. Current Fire Code: 2015 IFC with NCTCOG and Local Amendments.

**Submit three signed hard copies of reviewed plans, an electronic PDF copy of the reviewed plans and an electronic PDF copy of calculations, specifications and equipment lists.** Permits issued after FMO review. The FMO currently has no fee schedule for plan review, installation or permit.

**The following shall be reviewed by an approved third-party firm prior to submittal to the Fire Marshal's Office:**

- All new installations of fire alarm, fire sprinkler or alternative protection systems in buildings or tenant spaces 5,000 square feet or larger, or with an Occupant Load of 100 or more.
- Addition or relocation of fifteen (15) or more alarm devices.
- Addition or relocation of twenty (20) or more sprinkler heads.
- Any system the FMO requires to be reviewed by a third-party.

**The following firms are approved by the Fire Marshal's Office for third-party review:**

**Scott Whinery, P.E.**

**Knight Fire Protection Engineering, LLC**

1700 Yosemite Lane  
Keller, TX 76248

817-567-1763 office

405-269-9390 mobile

Email: [scott.whinery@knightfpe.com](mailto:scott.whinery@knightfpe.com)

**Ronald B Coker PE**

**Coker Engineering LLC**

**Life Safety & Fire Protection Engineering**

1540 Keller Pkwy #108-319

Keller TX 76248-3685

817-739-8333 mobile number

[ronald.coker@outlook.com](mailto:ronald.coker@outlook.com)

**Mark Hasenmyer, P.E.**

**MEH Fire Protection Engineering, LLC**

3367 Fireside Drive

Flower Mound, TX 75028

972-874-2662 office

Email: [pe@mehfpe.com](mailto:pe@mehfpe.com)

**Emily Kalina, P.E., Nicholas Kalina, CFPS**

**Traditions Fire Consulting, LLC**

P.O. Box 5587

Frisco, TX 75035

972-979-0631 office

Email: [traditionsfire@gmail.com](mailto:traditionsfire@gmail.com)

***The FMO shall be included in any communications regarding questions or discrepancies during the plan review process. All plans and plan reviews completed by the third party review firm shall be submitted to the FMO for final approval. The submitting contractor shall make payment of plan review fees to the third-party review firm.***

### **Contact Information:**



Fire Marshal  
Midlothian Fire Department

100 W. Avenue F  
Midlothian, Texas 76065  
972-775-7662

[Fire.marshall@midlothian.tx.us](mailto:Fire.marshall@midlothian.tx.us)

